



FOR CENTRAL OFFICE USE ONLY	ESTABLISHMENT NUMBER
-----------------------------	----------------------

Establishment Name Broken Arrow Campground	Name <input checked="" type="checkbox"/> Owner <input type="checkbox"/> General Manager Tina McQuerry
---	--

Physical Address 18227 Arrowhead Loop	City Eminence, MO	Zip 65466
--	----------------------	--------------

Mailing Address same as Physical	City	Zip
-------------------------------------	------	-----

County 203-Shannon	This inspection is a(n) <input type="checkbox"/> Initial <input type="checkbox"/> Annual <input checked="" type="checkbox"/> Follow-up	Telephone 417/830-5038	No. of Stories 1	No. of Rooms 9 cabins	Is the current lodging license displayed? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> N/A- new
-----------------------	---	---------------------------	---------------------	--------------------------	--

Rooms Inspected: <u>Big Log Cabin and Rustic Cabin</u>	Water Supply <input type="checkbox"/> Private <input checked="" type="checkbox"/> Public Water sample taken <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Wastewater <input type="checkbox"/> Private <input checked="" type="checkbox"/> Public Regulated by: <input type="checkbox"/> DHSS <input checked="" type="checkbox"/> DNR
Swimming Pools/Spas (check all that apply) Indoor pool <input type="checkbox"/> Outdoor pool <input type="checkbox"/> Spa <input type="checkbox"/> Pool larger than 2000 square feet <input type="checkbox"/>		

Please check if the following local ordinances apply <input type="checkbox"/> Fire Safety <input type="checkbox"/> Electrical Wiring <input type="checkbox"/> Plumbing <input type="checkbox"/> Swimming Pools/Spas <input type="checkbox"/> Fuel Burning Appliances	New Lodging Establishments <input type="checkbox"/> N/A Smoke detectors hardwired <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Fire alarm system installed <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Sprinkler system installed <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	Swimming Pool Certified <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Building Certified to National Standards or Occupancy Permit <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Historical Building <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A
---	---	--

Based on an inspection this day, the items marked "Out" below identify noncompliance in operations or facilities which must be corrected prior to issuance or renewal of your lodging license. Failure to comply with any time limits for corrections specified in this notice may result in revocation of your lodging license and/or prosecution. Owners may request a hearing before the Department Director upon filing a written request within ten days after receipt of this notice. (RSMo 315.005-065, 19 CSR 20-3.050)

In=In Compliance		Out=Not In Compliance, explain on additional page(s)				NO=Not Observed		N/A=Not Applicable			
Section A & B: Water Supply & Wastewater		In	Out	NO	N/A	Section E: Fire Safety		In	Out	NO	N/A
1. Approved source, construction and operation				✓		1. Textiles, hangings and mirrors				✓	
2. Complies with water quality standards				✓		2. Fire extinguisher type, inspected, and location				✓	
3. Chlorinator maintained and operated properly					✓	3. Vertical openings fire rated, self-closing					✓
4. Wastewater operation and maintenance				✓		4. Doors, self-closing and fire rated					✓
Section C: Sanitation/Housekeeping						5. Smoke detectors hardwired, installed, good repair					✓
1. Walls, floors and ceilings in good repair				✓		6. Evacuation route and plan, installed, available	✓				
2. Housekeeping practices and furnishings				✓		7. Stairs and ramps, maintained, storage					✓
3. Towels and bed linens clean				✓		8. Means of egress, number, maintained					✓
4. Mattresses and box springs clean				✓		9. Handrails and balconies maintained and appropriate	✓				
5. Pest control procedures				✓		Section F: Swimming Pools/Spas					
6. Ice machines, scoops, liners clean & protected					✓	1. Fence, gate adequate, proper closure mechanism					✓
7. Garbage storage and disposal				✓		2. Boundary line, pool depth properly marked					✓
8. Premises maintained, plant growth controlled				✓		3. Deck is clean and in good repair					✓
Food Inspection conducted according to 19CSR20-1.025						4. Lifesaving equipment adequate, good repair					✓
9. Food, equipment and single service/use	✓					5. Pool clarity, pH, disinfectant, temp maintained					✓
10. Food protected from contamination					✓	6. Steps, ladders, and handrails installed, good repair					✓
11. Facilities to wash, rinse and sanitize				✓		7. Adequate ventilation					✓
12. Handwashing facilities/hygienic practices				✓		8. Electrical outlets, proper protection & distance					✓
Section D: Life Safety						9. Records maintained and signs posted					✓
1. Combustible/toxic items usage and storage				✓		10. First aid kit available					✓
2. Building maintained to assure safe conditions	✓					11. Lighting adequate and in good repair					✓
3. CO detectors hard wired, installed, good repair					✓	Section G: Plumbing/Mechanical					
4. GFCI, outlets & switches installed, good repair	✓					1. Equipment adequate, good repair					✓
5. Exit signs installed, good repair				✓		2. Ventilation adequate, plumbing, restrooms					✓
6. Emergency lighting installed, good repair				✓		3. T & P relief valves adequate, good repair					✓
7. Electric panel protected, labeled, good repair				✓		4. Relief valve discharge pipes installed, adequate					✓
Required Annual Third Party Inspections						5. Backflow, air gaps, no cross connections					✓
1. Fire Alarm System				✓		Section H: Heating & Cooling					
2. Sprinkler System				✓		1. Unvented fuel-burning appliance/space heater					✓
3. Local Fire and Building Codes/Ordinances				✓		2. Fire resistant room or sprinkler head					✓
4. Current Boiler/pressure vessels MDPS Certification				✓		3. Location of heating/cooling units					✓
5. Backflow Device(s) Test				✓		4. Ventilation of appliances and utility rooms					✓
6. Liquid Propane Leak Test				✓		5. Operation and condition adequate					✓

INSPECTED BY (PRINT NAME and SIGN) Paula M. Cates <i>Paula Cates</i>	EPHS NUMBER 1453	AGENCY Mo Dept. of Health & S.S.	TELEPHONE 573/291-8047
---	---------------------	-------------------------------------	---------------------------

LICENSING YEAR 20 <u>23</u> / 20 <u>24</u>	APPROVED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	DATE INSPECTED 12/28/23	FOLLOW UP DATE
---	--	----------------------------	----------------

RECEIVED BY (PRINT NAME AND TITLE and SIGN) Tina McQuerry	PAGE 1 OF <u>2</u>
--	--------------------

